

115/34.5 kV Solar Power Plant & Substation

Elymus Schaffer - Team Lead

Baylor Clark - Team Co-lead and Testing

Liam Gossman - Client Correspondent

Eduardo Jimenez-Tzompaxtle - Submission, Research, and Testing Leader

Siti Mohd Radzi - Recorder and Testing

Chicheng Tang - Research and Testing Leader

Client- Black & Veatch: Adam Schroeder, Michael McDonald

Project Advisor- Dr. Venkataramana Ajarapu



BLACK & VEATCH



Project Vision



Two Main Components: (All Conceptual)

- 60 MW Solar Farm - Fall 2023
- 115/34.5kV Substation - Spring 2024

SPP Interconnect - Located on the NM/TX border

Project Plan

FALL 2023 - SOLAR POWER PLANT DESIGN

P
H
A
S
E



RESEARCH
(Week 1-3)

Collect data sheets for PV cells and solar farm components



PLANNING
(Week 4-6)

Finalize equipments and components for solar power plant



DESIGNING
(Week 7-9)

Create preliminary design sketch, and finalize actual design on AutoCAD



CALCULATION
(Week 10-12)

Perform voltage-drop calculation, economic analysis and do necessary amendments



SIMULATION
(Week 13-15)

Simulate solar circuit and analyze power flow

SPRING 2024 - SUBSTATION DESIGN

P
H
A
S
E



RESEARCH
(Week 1-3)

Collect data sheets for substation equipments



PLANNING
(Week 4-6)

Finalize equipments for substation



DESIGNING
(Week 7-9)

Designing one-line diagram of the substation



CALCULATION
(Week 10-12)

Perform power flow calculation and economic analysis




SIMULATION
(Week 13-15)

Simulate solar farm and substation power flow

Requirements- Functional


First Semester (Fall 2023)

- Research and select components
- Calculate equipment parameters, sizing, and layout
- Calculate voltage drops up to the substation
- Create solar layout drawings in AutoCAD



Second Semester (Spring 2024)


- Research and select substation equipment
- Calculate equipment parameters, sizing, and layout
- Create substation drawings in AutoCAD/BlueBeam
- Perform grounding analysis
- Simulate power flow of the overall system



Requirements- Non-Functional

Environmental

- Flat and continuous land
- High annual sunshine and solar irradiance
- Safe substation power for nearby communities
- Efficient land use



Economic

- Our solar plant must be able to produce enough power per year to recover initial investment and operational costs over 10 years.

Present Value		
Year	Installation cost	
10	\$63,912,000.00	Profit
O+M	Revenue	\$147,392,524.13
\$2,419,868.02	\$149,812,392.14	

Project Impact

User

- The electricity generated from the solar power plant will benefit the people of New Mexico, especially in Lovington.

For example,

- Residential consumers
- Commercial and Industrial Consumers
- Government facilities

User:

Cost savings: reduced electricity cost due to cheaper alternative.

Reliability: Reliable energy supply, reduced reliance on the main grid distribution.

Clean energy access: Reduce carbon footprint and promote sustainability.

Society:

Job opportunities: Construction, operation, and maintenance, benefiting local economies.


Infrastructure development: Enhance region's infrastructure, attract further investments and development.

Improved health: Mitigate air and water pollution, improve public health and quality of life.

Humanity:

Climate change mitigation: Renewable energy sources contribute to global efforts on reducing greenhouse gas emissions.


Conceptual Diagram



Design Standards & Practice - Solar Farm

Code	<i>Standards Description</i>
NEC690.8(B)	Overcurrent ratings shall not be less than 125% of the max current calculated
NEC690.8(A)	The maximum current shall be the sum of the short-circuit current ratings of the PV modules connected in parallel multiplied by correction multiplier, 125 percent.
NEC690.9	PV system dc circuit and inverter output conductors and equipment must be protected against overcurrent.
NEC 240.6	240.6(A) Fuses and Fixed-Trip Circuit Breakers: The standard ampere ratings for fuses and inverse time circuit breakers shall be considered 15, 20, 25, 30, 35, 40, 45, 50, 60, 70, 80, 90, 100, 110, 125, 150, 175, 200, 225, 250, 300, 350, 400, 450, 500, 600, 700, 800, 1000, 1200, 1600, 2000, 2500, 3000, 4000, 5000, and 6000 amperes.
NEC 210.19	Voltage drop would be 2% from DC, and 1% from AC side
NEC Table 8 Conductor Properties & NEC AWG Chart	Provides information on conductor properties, including ampacity, insulation types, and other specifications. NEC AWG Chart provides information on the ampacity of conductors based on their size (gauge) and the type of insulation which is crucial for ensuring that the conductors used in electrical installations can safely carry the expected current without overheating.
Lovington & Lea County Ordinance	The fence, wall or barrier required by [this subsection] shall not be less than eight (8) feet in height with no openings, holes or gaps larger than four (4) inches measured in any direction. Gates and doors opening directly into the area enclosed by a fence, wall or barrier, as required by this section, shall be equipped with a lock to keep the doors or gates securely closed and locked at all times. Tower sites located within industrial yard areas with existing secure fencing of the entire yard may construct secure fencing six (6) feet in height.

Overview of Solar Power Plant - 60MW



In a 60 MW solar farm, the solar panels connected in series for a string, to the total voltage of the string. Then, they are connected parallel into racks connected to the combiner box. The combiner box combines the power to the inverter, inverted into AC current. The inverter includes skids, would step-up the voltage to 34.5kV, before carried to the feeder to the substation.

PV Panels

- 550 W
- 50.2 Voc
- 13.89 Isc

Combiner Boxes

- Supports 1500 VDC
- 16 Inputs
- 1 Output

Inverters



- 1500 VDC Inputs
- Converts DC to AC
- Transformer steps up voltage

Array Parameter Tools

String Size		Electrical Rack Size			CB capacity		Array Design		Array Size					
				portrait or Landscape										
Location Dependent	Min Temp	-40 C	Designer Choice	Module width	3.72 ft	Datasheet (STC)	mod/string Isc	13.89 A	Designer Choice	Racks per row	16	Designer Choice	tilt	35
				module height	7.474 ft	Datasheet	multiplier	1.25						
Datasheet (STC)	Voc	50.2 V					nom Isc	17.3625	Designer Choice	rows per Array	24		table height proj	6.122342 ft
Datasheet (STC)	Ref temp	25 C	Designer Choice	Rack width	25 modules	Irr.	multiplier	1.25						
			Designer Choice	Rack height	1 modules		max Isc	21.70312 A	Designer Choice	Racks removed	2	Designer Choice	row space	10 ft
Datasheet	Temp Coeff of Voc	-0.0029 /C		Modules per rack			allowed current	350 A		Total Racks/Array	382		pitch	16.12234 ft
	Temp delta	-65		Rack width	93 ft	Choice: 200, 400A etc.	is this disconnect A?						Space for Inverter Maintenance	35 ft
	temp correction	1.19		Rack height	7.474 ft		strings per CB	16.12670		Total modules	9550		Array height	386.9362 ft
	V0c corrected	59.6627					Round down:	16						
Confirm possible with Panel type chosen	string voltage	1500 V					racks per CB	16	Datasheet (STC)	module capacity	550 W		Array width	1488 ft
	String size	25.14133								dc capacity	5252.5 kW		Ground Coverage Ratio	0.463580
	string size	25												
	Actual String Voltage	1491.6							Designer Choice	inverter capacity	4000 kW			
											4 MVA			
									:	ILR	1.313125			
									Industry standard					
									1.3					
	Input Information =													

System Design - Solar Layout

Based on Array Tool calculations




Inverter

1 array layout:


- a. One string of 25 series module per rack
- b. 16 racks in 1 row (16-input combiner box)
- c. 24 rows of racks (24 combiner box)
- d. 1 AC inverter

Combiner box


Conceptual Final Design Diagram



Overall Conceptual/Visual Sketch




AC Part



Solar panel -> Combiner Box -> Inverter skids (34.5kV) -> Feeder (34.5kV) -> Substation (115kV) -> Grid
(DC convert to AC)

Overview of Substation- 115/34.5kV




The electricity travels through transmission lines to a substation, where another step-up transformer boosts the voltage further to 115 kV. This elevated voltage is suitable for seamless integration into the broader electrical grid. The electricity is fed into the grid, facilitating its distribution to various consumers, including homes and businesses.

The circuit diagram to the left shows 115/34.5kV system substation.

Design Standards & Practice - Substation


Code	<i>Standards Description</i>
IEEE 80-2013	IEEE Guide for Safety in AC substation grounding
IEEE 998-2012	IEEE Guide for Direct Lightning Stroke Shielding of Substations
IEEE 485 -2020	IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stationary Applications
IEEE 605- 2008	IEEE Guide for Bus Design in Air Insulated Substations.
IEEE 1184-2006	IEEE Guide for Batteries for Uninterruptible Power Supply Systems

Conceptual Final Substation Design




① SUBSTATION ONE—LINE
N.T.S.

System Design - Substation Layout



Challenges & Risks


- Follow electrical codes/standards
 - IEEE/NEC and B&V requirements
- Accurate electrical calculations for design safety
 - Safety/Grounding
 - Battery Backup
 - Conductor spacing and sizing
- Project financial risks
 - Project should be financially viable
 - Need to keep cost in mind
- The team must also practice time management and good communication



Testing: Modeling




- **Power Flow Result**
 - Each PV array can produce 4.5 MW Power 12.5% more.
 - Total Power produce is 67.3 MW.

AutoCAD Design




Substation

ETAP Simulation Model



Feeder 1
Power Source



Feeder 2
Power Source

Conclusions

Group Member Contributions

Bell: Calculations (Both Substation and Solar Farm), Cost Analysis, Site Location Research

Eduardo: AutoCAD drawings, Combiner Box Research, Bus Verification

Chicheng: ETAP Design,

Eli: AutoCAD Drawings, Poster, Website Design

Liam: Calculations, Client and Faculty communication, Component Selection

Baylor: Bi-weekly reports, ETAP

All Members: Weekly Meetings, Leadership Roles

Q&A Session