

34.5/115 kV Solar Power Plant & Substation Senior Design Project

Senior Design Team 18 - May 2024

Siti Mohd Radzi, Baylor Clark, Eduardo Jimenez-Tzompaxtle,
Chicheng Tang, Eli Schaffer, Liam Gossman



BLACK & VEATCH



Agenda

- Safety Moment
- Calculation Documents
- AutoCAD Update
- ETAP
- Feedback



Safety Moment - Emergency Exits & Routes

- Location and prevalence of emergency exits are vital in public buildings and the workplace for safety of individuals in them
- Facilities hopefully will provide maps to aid in emergency exit routes
- Regulated by NEC and OSHA
- Signage indicating emergency exits should always be visible and not obstructed
- Keep paths of egress clear of any cords or obstructions
- Buildings should perform inspections to assure all emergency exit signs are working properly



Calculations

Battery Charger Equation:

$$A = L + \frac{AHR * K}{T}$$

A = Battery charger output current (A)

L = Continuous load current (A)

AHR = Amp hours removed of the battery system (Ah)

K = Efficiency factor (1.15 for flooded lead acid, 1.4 for NiCa)

T = Recharge time (hours)

Our system has a 100 Ah capacity with 60 Ah removed, and uses flooded lead acid batteries. Our continuous load is 3.576 A. Typical recharge times are usually 8, 12, or 24 hours.

A recharge time of 8 hours results in a charger output of 12.201 A (was 12.665 A before).

This will require the same battery charging system as before.



Calculations



Summary Margin Report

Customer: Iowa State University

Location: Lovington, New Mexico

Project: 11504.5 kV Solar Power Plant & Substation

Date Prepared: 4/10/24

Prepared By: Liam Gossman

Phone: 5153180150

E-Mail: lgossman@iastate.edu

String Parameters

Application: Utility

Lowest Temp (°F): 77.00

Min. Voltage (V_{oc}): 1.75

Design Margin: 1.10

Aging Factor: 1.25

Battery Load Details

Number of Cells: 60

Total Time (Minutes): 241.00

Amp Hour Removed: 59.96

Period	Time (Mins.)	Load
1	0.00	20.08 A
2	1.00	3.58 A
3	240.00	14.98 A

Line	Cell Model	Margin
1	CA-05M	1.0%
2	CA-03M (2 Strings)	1.0%
3	CC-05M	1.0%
4	CC-03M (2 Strings)	1.0%
5	8 OGI 110	27.7%
6	8 OGI 60 (2 Strings)	27.7%
7	ESG-05	86.4%
8	DSG-05	200.8%
9	EA-05M	108.6%
10	EC-05M	109.3%
11	GC-05M	765.6%
12	4 OPzS 200	123.4%
13	Vb 2408	867.6%


General Specifications

Cell Type*	Nominal Ah Capacity	Nominal Dimensions			Weight - Volumes				Short Circuit Current Amp					
		Length** in	mm	Width in	mm	Height in	mm	Unpacked lbs		kg	Electrolyte only† 1.215 SG lbs	gal	L	
3CA-3M	50	7.0	178	9.0	229	14.8	375	57.0	25.9	16.0	7.3	1.6	6.1	494
3CA-5M	100	7.0	178	9.0	229	14.8	375	74.0	33.6	15.0	6.8	1.5	5.7	972
3CA-7M	150	12.2	310	9.0	229	14.8	375	114.0	51.7	33.0	15.0	3.3	12.5	1434
3CA-9M	200	12.2	310	9.0	229	14.8	375	132.0	59.9	33.0	15.0	3.2	12.1	1862

* Prefix number indicates cells per unit. Suffix number indicates total plates per cell.

** 0.25" must be added between cells for spacing purposes when calculating total battery length.

† Nominal Ah Capacity is based on an 8 hour discharge rate to 1.75 final voltage per cell @ 77°F (25°C)



Our system will require 1 string of 20 CA-05M batteries

Calculations - BOM

Solar Component						
Component Type	SKU/Model Number	Quantity	Price	Datasheet Link	Total Price	Pricing Link
PV Panels	ZXM7-SHDB144-550/M	143250	\$270.00	Link	\$38,677,500.00	Link
Combiner Boxes	BHSZ-16-1-1500V	360	\$1,921.00	Link	\$691,560.00	Link
Inverters	PV5980-MWS-4000kVA-K-34 5-Dry	15	\$200,000.00	Link	\$3,000,000.00	Page 31
2" Conduit	2 in. x 10 ft. Sch. 40 PVC Conduit	1331	\$25.90	Link	\$34,472.90	Link
3" Conduit	3 in. x 10 ft. PVC Schedule 40 Conduit	798	\$60.78	Link	\$48,502.44	Link
600 MCM		21128.92	\$15.65	Link	\$330,667.60	Link
10 AWG		1395	\$0.38	Link	\$530.10	Link
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
Total Solar Farm Cost					\$42,783,233.04	


Misc Component						
Component Type	SKU/Model Number	Quantity	Price	Datasheet/Website Link	Total Price	Pricing Link
Bus Bars					\$0.00	
Fence (50' Segment)		340	\$633.00		\$215,220.00	Link
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
					\$0.00	
Total Misc Cost					\$215,220.00	

Substation Component						
Component Type	SKU/Model Number	Quantity	Price	Datasheet/Website Link	Total Price	Pricing Link
SEL-411L	0411L1X6X1C7CDXH5C424XX	1	\$11,170.00	Link	\$11,170.00	Link
SEL-311L	0311L03C0325XXXX	1	\$6,920.00	Link	\$6,920.00	Link
SEL-487E	0487E3X611XXC5X5H675XXX	1	\$8,860.00	Link	\$8,860.00	Link
GE Multilin T35	T35J03AKHF8MH6DM8RP6EU67WXX	1	\$4,500.00	Link	\$4,500.00	Link
SEL-751	751301ACA3A70851F00	2	\$1,270.00	Link	\$2,540.00	Link
ABB REU615	2rca025340a0001b	2	\$750.00	Link	\$1,500.00	Link
SEL-352	035211425H2X4XX	4	\$4,690.00	Link	\$18,760.00	Link
CB1	OHB 36.25 25	3	\$35,000.00	Link	\$105,000.00	Circuit Breaker (35 kV)
CB2	SPS2-123-40-2	1	\$95,500.00	Link	\$95,500.00	Circuit Breaker (115kV)
DS1	EV-H	8	\$7,000.00	Link	\$56,000.00	Discon. Switch (34.5 kV)
DS2	65742-A	2	\$20,000.00	Link	\$40,000.00	Discon. Switch (138 kV)
LA1	PEXLIM Q36-XN36 (H)	6	\$500.00	Link	\$3,000.00	Surge Arrestor (34.5kV)
LA2	AZES013G115144	3	\$2,000.00	Link	\$6,000.00	Surge Arrestor (138kV)
T1 (Power XFMR)	SF-9000000/15	1	\$2,000,000.00	Link	\$2,000,000.00	Page 7
T2 (Station Power)	MT-PML-R50-1P-GMA-50KVA-SZ-LT-DF-Z6-BB-CS-2BZ-M1	1	\$18,641.04	Link	\$18,641.04	Link
CT1	G953000DA	24	\$0.00	Link	\$0.00	
CT2	OSKF123	6	\$15,000.00	Link	\$90,000.00	Current XFMR (138kV)
PT1	G840520TA	3	\$2,000.00	Link	\$6,000.00	Volt XFMR (34.5kV)
PT2	Unavailable	1	\$7,000.00	Link	\$7,000.00	Cap Volt XFMR (138kV)
Battery MTS	GF224NR	1	\$842.73	Link	\$842.73	Link
Battery Backup	3CA-5M	20	\$1,152.75	Link	\$23,055.00	Link
Total Substation Cost					\$2,505,288.77	

Total Project Materials Cost	\$45,420,766.47
-------------------------------------	------------------------



AutoCAD - Grounding



SDMAY23-27 had 315 grounding rods

- 315 rods in 140'x100' area
 - 0.0225 rods/ft²
- We have 18700 ft² (170'x110')
 - Total of 420 rods

This seems low for our application. Assume 8.35% impedance for the transformer. Reference the transformer nameplate on the last drawing.

$$\text{Line current} = \frac{90\text{MVA}}{\sqrt{3} \times 34.5\text{kV}} = 1506.13\text{A}$$

Infinite Bus method:
 $I_{sc} = I_L / \%Z =$


$$1506.13 / 0.0835 = 18037\text{A} = 20\text{kA}$$



- Using 60MVA instead of 90MVA we get a line current of 1004A
- Dividing by 0.0835 we get 12kA for I_{sc}



AutoCAD - Grounding



SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	CONDUIT		UNDERGROUND
	CH FEEDER		RIGID BUS
	TRENCH		STRAIN BUS




ST TABLE	
SHEET NUMBER	SHEET TITLE
SS100	SUB DESIGN SYMBOLS
SS101	SUB ONE-LINE
SS102	SUB KEY PLAN
SS103	SUB ONE-LINE DETAILS
SS104	SUB GROUNDING INFO
SS105	SUB THREE-LINE
SS106	SUB ONE-LINE PLAN VIEW
SS107	SUB SECTION VIEW
SS108	SUB SITE ENLARGED
SS109	SUB RELAY INFO
SS110	CB1-X DATASHEET
SS111	CB2-X DATASHEET
SS112	DS1-X DATASHEET
SS113	DS2-X DATASHEET
SS114	LA1-X DATASHEET
SS115	LA2-X DATASHEET
SS116	T1 NAMEPLATE

- Adding stingers before 90%




AutoCAD - Updates



ST TABLE	
SHEET NUMBER	SHEET TITLE
SS100	SUB DESIGN SYMBOLS
SS101	SUB ONE-LINE
SS102	SUB KEY PLAN
SS103	SUB ONE-LINE DETAILS
SS104	SUB GROUNDING INFO
SS105	SUB THREE-LINE
SS106	SUB ONE-LINE PLAN VIEW
SS107	SUB SECTION VIEW
SS108	SUB SITE ENLARGED
SS109	SUB RELAY INFO
SS110	CB1-X DATASHEET
SS111	CB2-X DATASHEET
SS112	DS1-X DATASHEET
SS113	DS2-X DATASHEET
SS114	LA1-X DATASHEET
SS115	LA2-X DATASHEET
SS116	T1 NAMEPLATE



AutoCAD - Updates




SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	CONDUIT		UNDERGROUND
	CH FEEDER		RIGID BUS
	TRENCH		STRAIN BUS

ST TABLE	
SHEET NUMBER	SHEET TITLE
SS100	SUB DESIGN SYMBOLS
SS101	SUB ONE-LINE
SS102	SUB KEY PLAN
SS103	SUB ONE-LINE DETAILS
SS104	SUB GROUNDING INFO
SS105	SUB THREE-LINE
SS106	SUB ONE-LINE PLAN VIEW
SS107	SUB SECTION VIEW
SS108	SUB SITE ENLARGED
SS109	SUB RELAY INFO
SS110	CB1-X DATASHEET
SS111	CB2-X DATASHEET
SS112	DS1-X DATASHEET
SS113	DS2-X DATASHEET
SS114	LA1-X DATASHEET
SS115	LA2-X DATASHEET
SS116	T1 NAMEPLATE



AutoCAD - Updates


- CT
- × PT
- RELAY CONNECTION



ST TABLE	
SHEET NUMBER	SHEET TITLE
SS100	SUB DESIGN SYMBOLS
SS101	SUB ONE-LINE
SS102	SUB KEY PLAN
SS103	SUB ONE-LINE DETAILS
SS104	SUB GROUNDING INFO
SS105	SUB THREE-LINE
SS106	SUB ONE-LINE PLAN VIEW
SS107	SUB SECTION VIEW
SS108	SUB SITE ENLARGED
SS109	SUB RELAY INFO
SS110	CB1-X DATASHEET
SS111	CB2-X DATASHEET
SS112	DS1-X DATASHEET
SS113	DS2-X DATASHEET
SS114	LA1-X DATASHEET
SS115	LA2-X DATASHEET
SS116	T1 NAMEPLATE




AutoCAD - Updates



ST TABLE	
SHEET NUMBER	SHEET TITLE
SS100	SUB DESIGN SYMBOLS
SS101	SUB ONE-LINE
SS102	SUB KEY PLAN
SS103	SUB ONE-LINE DETAILS
SS104	SUB GROUNDING INFO
SS105	SUB THREE-LINE
SS106	SUB ONE-LINE PLAN VIEW
SS107	SUB SECTION VIEW
SS108	SUB SITE ENLARGED
SS109	SUB RELAY INFO
SS110	CB1-X DATASHEET
SS111	CB2-X DATASHEET
SS112	DS1-X DATASHEET
SS113	DS2-X DATASHEET
SS114	LA1-X DATASHEET
SS115	LA2-X DATASHEET
SS116	T1 NAMEPLATE




AutoCAD - Updates



ST TABLE	
SHEET NUMBER	SHEET TITLE
SS100	SUB DESIGN SYMBOLS
SS101	SUB ONE-LINE
SS102	SUB KEY PLAN
SS103	SUB ONE-LINE DETAILS
SS104	SUB GROUNDING INFO
SS105	SUB THREE-LINE
SS106	SUB ONE-LINE PLAN VIEW
SS107	SUB SECTION VIEW
SS108	SUB SITE ENLARGED
SS109	SUB RELAY INFO
SS110	CB1-X DATASHEET
SS111	CB2-X DATASHEET
SS112	DS1-X DATASHEET
SS113	DS2-X DATASHEET
SS114	LA1-X DATASHEET
SS115	LA2-X DATASHEET
SS116	T1 NAMEPLATE



ETAP PV & Substation Power Flow Analysis



ETAP PV & Substation Power Flow Analysis

DC Cable Editor - Cable4

Info

Southwire-PV	Non-Mag.	60 Hz	Code : 10
USE2	100 %	2.0 kV	1/C CU 10 AWG/kcmil

Info

ID: Cable4

From: Inv2-6 1500 V

To: PVA1-003
PVA1-003's Equipment Cable

Revision Data

Base

Equipment

Tag #

Name

Description

Condition

Service: In Out

State: As-Built

Conductor

/ Phase: 50

of Splices: 0

Length

Length: 93 ft

Tolerance: 0 %

Library

Library...

OK Cancel

$\#/\text{Phase} = \text{Amps}/\text{Ampacity}$
Base on the NEC table 310.15(B)(16), the smallest Ampacity for copper 600kcmil wire is 350A, So the $\#/\text{Phase} = 1$ for the DC cable. And we supposed use 600kcmil wire in this model.

Reference:
<https://www.physicsforums.com/threads/determining-conductors-per-phase-451-amps-ampacity.585804/>



Questions

-

Feedback and Updates

- Tasks: Updates
 - Bell: Design documents
 - Liam:
 - Eli:
 - Baylor:
 - Eduardo:
 - Chicheng:

