

34.5/115 kV Solar Power Plant & Substation Senior Design Project

Senior Design Team 18 - May 2024

Siti Mohd Radzi, Baylor Clark, Eduardo Jimenez-Tzompaxtle,
Chicheng Tang, Eli Schaffer, Liam Gossman



BLACK & VEATCH



Agenda

- Safety Moment
- Calculation Documents
- AutoCAD Update
- ETAP
- Feedback



Safety Moment - Hazardous materials & chemicals

Types of Chemicals

- **Toxic:** cause death or sickness
- **Corrosive:** burns or irritation on the skin and eyes
- **Flammable:** easy to catch on fire
- **Reactive:** explosion in specific scenarios
- **Radioactive:** Cancer causing sometimes or burns to skin

Risks Working with Chemicals

- **Contact:** with eyes or skin
- **Ingestion:** with beverages or food
- **Breathing:** inhaling toxic gases
- **Injection:** accidental gash with contaminated item

Be aware of surrounding chemicals and the safety guidelines. If needed, use protective equipment. Have access to emergency showers and eyewash kits.



STATE

Calculations

AC Load Calculation :

Total worst case load:
41.652 kW or
45.817 (10% worst case
scenario added)

Assumptions

- 180VA load per Outlet assumed as worst case
- The worst case scenario will be as follows:
 - Time of day: Day (no lights on).
 - Temperature: 90 deg F (all Transformer fans on).
 - Battery: Deep discharge (charger on full).
- Worst case tripping conditions shall be as follows:
 - 115/34.5 kV Transformer fault
 - (1) 115 kV Breaker will trip
 - (4) 34.5 kV Breaker will trip

* - Ratings estimated.

Calculations

The continuous 120/240VAC single phase loads are as follows:

	Quantity	Load/Unit(W)	Amps (ea)	Voltage(V)	Total(W)	Amps Total	
AC Panel - Control Building	Breaker Receptacle and Lights	5	210	1.75	120	1,050	8.75
	Transformer Fans	1	24,000	100.00	240	24,000	100.00
	Transformer Sump Pump	1	2,000	8.33	240	2,000	8.33
	Control House Lighting	20	36	0.30	120	720	6.00
	Yard Lights (Assuming lights are off)	0	55	0.46	120	0	0.00
	HVAC System	1	10,000	41.67	240	10,000	41.67
	Fire Detection Equipment	1	150	1.25	120	150	1.25
	Exhaust Fan	1	132	1.10	120	132	1.10
	AC Battery Charger	1		#DIV/0!		0	#DIV/0!
	Power Outlet		180	1.50	120	0	0.00
				#DIV/0!		0	#DIV/0!
				#DIV/0!		0	#DIV/0!
				#DIV/0!		0	#DIV/0!
				#DIV/0!		0	#DIV/0!
				#DIV/0!		0	#DIV/0!
	Worst Case Tripping:						
High Side Breaker Trip	1	720	3.00	240	720	3.00	
Low Side Breaker Trip	4	720	3.00	240	2,880	12.00	
Total Worst Case AC Panel Load					41,652	#DIV/0!	
Total Worst Case Load (+10 %)					45,817	#DIV/0!	

Sizing Recommendations:
Station Service - XXXkVA
MTS, Safety Switch - XXA

recommend XXXA Station Service Equipment

1. Breaker tripping load is temporary
2. 10% worst case scenario is added to the final value

https://docs.google.com/spreadsheets/d/1hwF8cv3VBiy1_Yih5wwwBzs9P8UB_BBc/edit?usp=sharing&ouid=101132689819119398819&rtpof=true&...



Calculations

DC Load & Battery Sizing :

DC Load Profile	Components	Load Current (A)	Nominal Voltage (V) DC	Inception and Active Shutout Time (Min.)	Power Requirement (remember to account for # of relays required)	Number of Components
	34.5kV Breaker:	Tripping Current: 3.3A Closing Current: 2.6A	70 – 140 90 - 140	0 - 1	231 - 343W 234 - 364W	4
	115kV Breaker:	Tripping Current: 3.3A Closing Current: 2.6A	70 – 140 90 - 140	239- 240	462 - 924W 324 – 504W	1
	SEL-411L (Line)	0.28 A	125	1 - 240	35 W / 90 VA	1
	SEL-311L (Line)	0.2 A	125	1 - 240	25 W	1
	SEL-487E (XFMR)	0.28 A	125	1 - 240	35 W / 90 VA	1
	GE Multiilin T35 (XFMR)		125	1 - 240	Unknown	1
	SEL-751 (Bus/Feeder)	0.2 A	125	1 - 240	25 W / 55 VA	2
	ABB REU615 (Bus/Feeder)	0.144 A	125	1 - 240	18 W	2
	SEL-451 (Breaker)	0.28 A	125	1 - 240	35 W / 90 VA	4
	Battery Monitoring Equipment	0.024A	50 -180	1 - 240	3VA	1
	DC Ammeter	0.048A	125	1 - 240	6VA	1
	DC Voltmeter	0.048A	120	1 - 240	6VA	1
	SACO Annunciator (L8)	0.12 A	125	1 - 240	15 W	Unknown
	Edwards Bell	0.012A	125	1 - 240	1.5VA	1
	Power Line Indicating Lamps (LEDs)	0.017A	125	1 - 240	2.125 W	8
			60 cell system	Continuous Load	Discontinuous Load Current	
				T = 0	T = 1 min	T = 240 min

- Fill out the DC Load Profile below. Read the assumptions and notes below the table.
- Determine and record the current load amounts for 3 periods:
 - Period 1: T=0min Fault occurs, relays detect. Breakers Trip due to relay operation.
 - Period 2: T=1min Breakers are open, everything else is simply running.
 - Period 3: T=240min Fault is cleared, relays operate to close Breakers
- Create an account for the Enersys Battery Sizing Program <https://bsp.enersys.com/bsp/index.do> and enter your parameters to obtain a full battery system and PDF of the sizing report. This should give you a breakdown of the Amp-hours for the time periods determined.

Some notes on the table above and how to use it:

- Continuous load will be the above parameters **NOT INCLUDING** the trip coils from the breakers.
 - Keep in mind, there will be more than one of each type of relay, use your zones of protection to keep in mind how many of each there are.
 - 34.5kV Feeder position (array) – Primary SEL-411L, Backup SEL-451
 - Transformer Position – Primary SEL-487E, Backup SEL-451
 - 115kV Line Position – Primary SEL-411L, Backup SEL-311L
- There will be 3 periods of operation:
 - Period 1: T=0min Fault occurs, relays detect. Breakers Trip due to relay operation.
 - Period 2: T=1min Breakers are open, everything else is simply running.
 - Period 3: T=240min Fault is cleared, relays operate to activate the Breaker close-coils, bringing the Breakers back into the closed position for normal operation.
- Last item listed are LED Lamps. These will be placed around the substation yard to illuminate important equipment and cabinets. Assume we have 8 of these.
- Assume a 60 Cell system
- Use device cut-sheets to find SEL parameters (you will need to create an account, should be quick to create!) for the relay current-draw.

https://docs.google.com/spreadsheets/d/1xRuWZ2yvrR49pMpPjpyQim3Ds8Mtx1fyL_kv4MVxrcck/edit?usp=sharing



Grounding Calculations

Requirements:

- Find the uniform soil resistivity (ρ_u) in ohm-m using the given soil resistivity measurements.
- Find the minimum conductor size (in kcmil) for a copper, soft-drawn grounding conductor. (Although the minimum value may be significantly smaller, 4/0 AWG is typically the smallest size conductor used in a substation grounding grid)
- Find the tolerable Step (E_{STEP}) and Touch (E_{TOUCH}) voltages with a surface layer derating factor $C_s = 0.8$. (Note that equations are 31-33 are labeled incorrectly as step equations. They are touch equations)
- Design a square grid for the given substation area and find the maximum step (E_s) and maximum mesh/touch (E_m) voltages. Refine the ground grid design as needed so that the maximum step/touch voltages are less than the tolerable step/touch voltages that were found in problem 3. If needed, use ground rods with a length of 20'.
- Provide a drawing of the ground grid in the proposed substation area showing grid spacing distances. Industry standard typically has the ground grid extend 3 feet outside the fence line.
- Provide a short report that includes references, any assumptions made, and final results (please include equations and calculations, even if hand-written).

Outer dimension of substation fence

160' by 100' (ft) or
48.768 by 30.48 (m)

Grid Dimension

16X10
With spacings between conductor =
10ft or 3.048 m

Tolerable Touch & Step Voltage based on the parameters

$E_{touch} = 377.312V$
 $E_{step} = 1263.1755$

Maximum Touch & Step Voltage, based on the substation dimension and parameters

$E_{touch(max)} = 277.759V$
 $E_{step(max)} = 1075.6457$

1 Calculation for the uniform soil resistivity (pa) in ohm-m				
Probe Spacing (ft)	Apparent Resistivity (ohm-m)			
1	120			
2	85	pa	56.28571429	ohm-m
3	65			
6	48			
10	32			
20	24			
30	20			
7	394			

2 Calculation for Minimum Conductor Sizing						
Description	Material conductivity (%)	α_s factor at 20 °C (1/°C)	K_a at 0 °C (0 °C)	Fusing ² temperature T_m (°C)	ρ_s 20 °C ($\mu\Omega\cdot\text{cm}$)	TCAP thermal capacity (J/(cm ² ·°C))
Copper, annealed soft-drawn	100.0	0.00393	234	1083	1.72	3.42
ar	K0		Tm	pr		TCAP
0.00393	234		1083	1.72		3.42

3 Calculation for Tolerable Step Voltage			
$E_{step50} = (1000 + 6C_s \cdot \rho_s) \frac{0.116}{\sqrt{f_1}}$		E(step50)	1263.175554 V

4 Calculation for Tolerable Touch Voltage			
$E_{touch50} = (1000 + 1.5C_s \times \rho_s) \frac{0.116}{\sqrt{f_1}}$		E(touch50)	377.3121784 V

5 Calculation for Maximum Step Voltage			
$E_s = \frac{\rho \cdot K_s \cdot K_i \cdot I_G}{L_S}$		Es	1075.645723 V

6 Calculation for Maximum Touch Voltage			
$E_m = \frac{\rho \cdot K_m \cdot K_i \cdot I_G}{L_M}$		Em	277.7595728 V

Conductor sizing	158.35	kcmil
	80.235945	mm
	3/0	size
	size	4/0



Given parameters for grounding				
Parameters	Value	Unit	Symbols	
Maximum grid current	32	kA	Ig	
Fault duration for conductor sizing	1	s	tc	
Shock duration	0.5	s	ts	
Surface layer thickness	0.15	m	hs	
Surface layer resistivity	3000	ohm-m	ps	
Body weight	50	kg	w	
Ambient temperature	40	C	Ta	
Grounding conductor depth	0.15	m	h	
Grid reference depth	1	m	h0	
Dimension of fence (x)	160,48.768	ft, m		
Dimension of fence (y)	100, 30.48	ft,m		
Grid dimension	16 x 10			

Parameters to calculate/fin					
Parameters	Value	Unit	Symbols	Value	Unit
Number of parallel conductors	12.47723374		n		
Spacing between n parallel conductors	10	ft	D	3.048	m
grid conductor diameter	0.0383333	ft	d	0.01168398984	m
Total length of conductor in the horizontal grid	3200	m	Lc	975.36	m
Perimeter length of grid	520	m	Lp	158.496	m
Area of the grid	16000	m^2	A	4876.8	m
Max length in the x direction	160	ft	Lx	48.768	m
Max length in the y direction	100	ft	Ly	30.48	m
Max distance between any two points on the grid	188.6796226	m	Dm	57.50954898	m
Total length of rod	12800	m	LR	3901.44	m
Length of each rod	20	m	Lr	6.096	m
Number conductors	12.30769231		na	3.751384615	m
Number conductors	1.013775241		nb	0.3089986935	m
Number conductors	1		nc	0.3048	m
Number conductors	1		nd	0.3048	m
Number of grounding rods	640		r	195.072	m

Calculations

High voltage buses in substations - interconnect the various pieces of equipment to form the desired bus configuration.

- provide controlled paths for current to flow between the connected equipment
- The basic task of the substation bus designer is
 - select the bus conductor, components, and arrangement to meet criteria and being cost effective.

Bus calculation:

1. Ampacity
2. Bus Force
3. Maximum Allowable Span

Parameters based on the IEEE 605, and conductor material/type/size

Variable	Description	Value	Unit
ΔT	Temperature difference between ambient and conductor surface	50	°C
T2, Tc	Conductor Temperature	90	°C
ϵ	Emissivity	0.2	new al
		0.5	Weathered al
Ta	Ambient Temperature	40	°C
ϵ'	Solar absorption	0.5	
E	Modulus of elasticity for aluminum	68.9x109	N/m2
FG	Gravitational Force	33.7	N/m
σ (allowable)	Allowable stress of material accounting for welds	120	MPa
wc	Specific weight of aluminum	26500	N/m3
wi	Ice weight	8820	N/m3
ri	Equivalent uniform radial ice thickness	0.00635	m
C	Constant, for metric units	0.613	
		40	m/s
V	Extreme wind velocity	144	km/h
Cf	Force coefficient for rigid tubular bus	1	
Gf	Gust response factor	0.85	
I	Importance factor	1.15	
ISC	Short-circuit current	15	kA
r	Constant based on type of fault and conductor location	0.866	
Kf	Mounting structure flexibility factor	1	
Df	Half cycle decrement factor	0.927	
η	Allowable deflection as a fraction of span length	0.0067 (1/150)	
C'	Conductivity, % IACS. For 6101-T6 alloy per Table 2	55	

Variable	Description	Value	Unit	Remarks
D	Diameter	0.0889	m	
t	Wall thickness	0.0054864	m	
Hc	Altitude of sun latitude	80	degree	from H.5
Zc	Azimuth of sun	180	degree	from H.5
Zl	Azimuth of conductor line	0	degree	from H.5
ϵ'	Solar absorption	0.5		from H.6
Qs	Solar heat gain	1032.6	W/m	
A'	Projected area of conductor by unit length	0.0889	m	A'=D
K	Heat multiplying factor	1.027432		From C.4
	Elevation	274.32	m	Assumption
F	Skin effect coefficient	1		
D	Conductor outside diameter (flexible)	0.0286	m	
C'	Conductivity (flexible)	61		
Ac	Cross-sectional area	0.00	m	
A'	Projected area of conductor by unit length (flexible)	0.0286		
Tc	Conductor Temperature (flexible)	75	°C	
Ta	Ambient temperature(flexible)	25	°C	

Calculations

Bus calculation:

1. Ampacity

$$R = \frac{1.724 \times 10^{-6}}{C' A_c} \left(1 + \frac{0.00403 C'}{61} (T_2 - 20) \right)$$

$$A_c = \frac{\pi}{4} \times [(D)^2 - (D - 2 \times t)^2]$$

$$q_c = 3.561 D^{-0.4} A \Delta T$$

$$A = \pi D l$$

$$q_r = 5.6697 \times 10^{-8} \varepsilon A [(T_c + 273)^4 - (T_a + 273)^4]$$

$$\theta = \cos^{-1} [\cos H_c \cos (Z_c - Z_1)]$$

$$q_s = \varepsilon' Q_s A' K \sin(\theta)$$

$$I = \sqrt{\frac{q_c + q_r - q_s}{RF}}$$

1 Rigid bus calculation			
Variable	Description	Value	Unit
R	DC resistance	0.000027	ohm/m
Ac	cross-sectional area	0.001438	m ²
A	surface area by unit length	0.2792875869	m ² /m
qc	Forced convection heat loss	130.9281126	W/m
qr	radiation loss from a surface	61.47963125	W/m
θ	effective angle of incidence of sun (theta)	1.692969374	rad
θ	effective angle of incidence of sun (angle)	97	degree
qs	heat gained from incident solar radiation	46.80666342	W/m
I	Allowable current (I)	2322.204256	A

2 Flexible bus (conductor) calculation			
Variable	Description	Value	Unit
R	DC resistance	0.000075	ohm/m
A	surface area by unit length	0.08984954989	m ² /m
qc	Forced convection heat loss	66.29968585	W/m
qr	radiation loss from a surface	19.7677	W/m
qs	heat gained from incident solar radiation	15.05816168	W/m
I	Allowable current (I)	973.0311689	A
I	Rating of two conductor	1946.062338	A

should be greater than the maximum load current

<https://docs.google.com/spreadsheets/d/1B0NZYBSkD5nU1l6Lladosi6QVM00BY21F-aINrFiGwY/edit?usp=sharing>



Calculations

Bus calculation:

1. Bus force




Figure 8—Extreme radial glaze ice thickness (in) Western United States (except the Pacific Northwest), 50-year return period with concurrent 3 s wind speeds²

Bus calculation (IEEE 80) - Bus Force

Symbols	Variables	Value	Unit	Remarks
wc	Conductor weight	26500		H.6.1
Do	Conductor outside diameter	0.0889	m	
Di	Conductor inside diameter	0.0762	m	
tc	Conductor wall thickness	0.0054864	m	
w1	Ice weight	8820		
r1	Uniform radial thickness of ice	0.00635		
C	Constant	0.613		
V	Extreme wind speed without ice	44.7		racking
Cf	Force coefficient	1		
Kz	Height and exposure factor	1.09		substation height = 50 ft
Gf	Gust response factor	0.85		
I	Importance factor of structure	1.15		
I'	Constant based on fault and location	0.866		
Isc	Symmetrical RMS fault current	688.0369379		1/2*sqrt(2)
D	Conductor spacing center-to-center	2.44		
Df	Half-cycle decrement factor			
Kf	Mounting structure flexibility factor	1		30ft bus
Kf	Mounting structure flexibility factor	0.95		40ft bus

figure 20 IEEE

Symbols	Equations	Value	
Fc	Conductor unit length	38.00997229	
Fi	Ice unit weight	16.75938	
Fwi	Wind load with ice	132.5907578	H.21
Fw	Wind load without ice by unit length	116.0169421	H.20
Fsc	Short circuit force	0.2444432507	H.22
Qs	Snow load	11-20 psi	
Fsc-corr	Short circuit force corrected	0	

<https://docs.google.com/spreadsheets/d/1B0NZYBSkD5nU1I6lladosi6QVMOQBY21F-alNrFIGwY/edit?usp=sharing>

Calculations

Bus calculation: 3. Maximum allowable span

Bus calculation (IEEE 80) - Maximum allowable span

Symbols	Variables	Value	Unit	Remarks
Fc	Conductor unit weight	38.00997229		
Fd	Damping material unit length			
Fi	Ice unit weight	16.75938		
dmax	Vertical deflection limit			
Do	Conductor outside diameter	0.0889		
Di	Conductor inside diameter	0.0762		
E	Young's modulus of conductor	7000000000	Aluminium	
n	Fraction of allowable span limit	0.0066666667		
Fv	Total vertical force	54.85910402		
Fh	Total horizontal force	132.8352011		
Fw	Wind force	116.0169421		
Fwi	Wind force with ice	132.5907578		

Symbols	Equations	Value		
Fg	Total gravitational force	54.85910402	H.23	
J	Bending moment of inertia	0.000001411076	H.23	
Lv	Allowable span	0		
Lv (using n)	Allowable span	9.732474516		
Equations for fiber stress				
Symbols	Equations	Value		
Ft1	Total force on conductor	143.7174726		
Ft2	Total force on ice and short circuit	143.7174726		
Ls	Allowable length with two pinned ends	14.56195825	Fiber stress	H.7.2
Ls	Allowable length fixed-fixed ends	17.83468368		

<https://docs.google.com/spreadsheets/d/1B0NZYBSkD5nU1l6lLadosi6QVM00BY21F-aINrFIGwY/edit?usp=sharing>




AutoCAD - Updates


SHEET LIST TABLE			
SHEET NUMBER	SHEET TITLE	SHEET NUMBER	SHEET TITLE
E100	PROJECT TITLE	SS100	SUB DESIGN SYMBOLS
S100	SITE PLAN	SS101	SUB ONE-LINE
S101	SITE KEYPLAN	SS102	SUB KEY PLAN
S102	SITE WIRING	SS103	SUB ONE-LINE DETAILS
PV100	SOLAR KEY PLAN	SS104	SUB GROUNDING INFO
PV101	OVERALL ARRAY LAYOUT	SS105	SUB THREE-LINE
PV102	ARRAYS 1 - 12 LAYOUT	SS106	SUB ONE-LINE PLAN VIEW
PV103	ARRAYS 13 - 15 LAYOUT	SS107	SUB SECTION VIEW
PV104	WIRING ARRAYS 1 - 12	SS108	SUB SITE ENLARGED
PV105	WIRING ARRAYS 13 - 15	SS109	FUTURE
PV106	SOLAR DESIGN DETAILS	SS110	CB1-X DATASHEET
PV107	AC ONE LINE	SS111	CB2-X DATASHEET
PV108	DC ONE LINE	SS112	DS1-X DATASHEET
PV109	STRING ONE LINE	SS113	DS2-X DATASHEET
PV110	PANEL DATASHEET	SS114	LA1-X DATASHEET
PV111	COMBINER BOX DATASHEET	SS115	T1 NAMEPLATE
PV112	SKID INVERTER DATASHEET		




AutoCAD - Updates



AutoCAD - Updates



AutoCAD - Updates




① SUBSTATION ONE-LINE
N.T.S.

② SUBSTATION PROTECTION ZONES
N.T.S.




AutoCAD - Updates



① SUBSTATION SITE DETAIL



AutoCAD - Updates



ETAP - Substation

2-Winding Transformer Editor - T1

Info: 90 MVA ANSI Liquid-Fill Other 65°C 115 34.5 kV

Rating

Impedance

Voltage Rating: kV FLA 451.8 Nominal Bus kV 0 Z Base MVA 90

Prim. 115 Sec. 34.5 1506 Other 65

Power Rating: MVA Aert - Max MVA 90

Rated 90 Other 65 Derated 90

Installation: Altitude 3300 ft Ambient Temp. 30 °C

MFR

Type / Class: Type Liquid-Fill Sub Type Other Class Other Temp. Rise 65

Buttons: [Back] [Forward] [Home] [Print] [OK] [Cancel]

2-Winding Transformer Editor - T1

Info: 90 MVA ANSI Liquid-Fill Other 65°C 115 34.5 kV

Impedance

Impedance: %Z X/R R/X %X %R

Positive 8.5 34.1 0.029 8.496 0.249

Zero 8.5 34.1 0.029 8.496 0.249

Typical Z & X/R Typical X/R

Z Base: MVA 90 Other 65

Z Variation: %Z %Z Variation

@ -5 % Tap 8.5 0

@ 5 % Tap 8.5 0

Z Tolerance: + 0 %

No Load Data (Unbalanced and Transient Stability Analyses)

	% FLA	kW	% G	% B
Positive	0.5	112.5	0.125	0.484
Zero	0.5	112.5	0.125	0.484

Buned Delta Winding Zero Sec. Impedance Typical Value

Eddy Current Loss

Buttons: [Back] [Forward] [Home] [Print] [OK] [Cancel]

High Voltage Circuit Breaker Editor - CB2-1

Info: 126 kV 0.01 sec 0 kA 0 kA

Rating

Standard: ANSI IEC IEC/IEEE

Library Info: MFR none Model none

Rating: Rated kV 126 Rated Amp 3150 TRV 0

Making Peak 0 Breaking 0 Time Constant 45 % dc 80.07

I_{tr} 0 I_{tr} 3 User-defined Tk 3

Min. Delay 0.01 Break Time 0.02 FPC Factor 1.3 T close 0.02

Application/Association: Association ID Reverse Direction

Buttons: [Back] [Forward] [Home] [Print] [OK] [Cancel]

High Voltage Circuit Breaker Editor - CB01-4

Info: 38 kV 5 Cy 16 kA 43 kA

Rating

Standard: ANSI IEC IEC/IEEE

Library Info: MFR Cutler/Hammer Model 380VCP-WH16

Rating: Max kV 38 Cont. Amp 1600 Standard 5YM Cycle 5 CPT 3 Time Constant 45


Rated Int. 16 Max Int. 16 C & L ms 26 C & L Peak 43 S Factor 1.1031 % dc 32.92

Application/Association: Association ID TRV Reverse Direction

Buttons: [Back] [Forward] [Home] [Print] [OK] [Cancel]



ETAP - PV Power Flow



ETAP - PV Power Flow

Cable Editor - Cable1

Info

Physical

Impedance

Configuration

Loading

Ampacity

Protection

Sizing - Phase

Sizing - PE & N

Reliability

Routing

Remarks

Comment

Option

Positive Seq. Library Zero Seq. Library

Calculated Calculated

User-Defined Cable-Z External File.xl

Units

Ohms per 1000 ft Ohms

Frequency

Project 60 Hz

Data Hz

Impedance - Library

	R	X	L	Z	X/R	C	Y
Pos.	0	0	0	0	0	0	0
Zero	0	0	0	0	0	0	0

Calculated Impedance

Layout Flat Conduit Type Steel

	R	X	L	Z	X/R	C	Y
Pos.	0	0	0	0	0	0	0
Zero	0	0	0	0	0	0	0

Cable Temperature

Base 75 °C Min. 75 °C Max. 75 °C

Susceptance Calculation: Cable insulation thickness or outside diameter is 0.
Impedance Calculation: A cable library must be selected from the Info page.

OK Cancel

DC Cable Editor - DC Cable2

Info

Physical

Impedance

Configuration

Loading

Ampacity

Protection

Sizing - Phase

Sizing - PE & N

Routing

Remarks

Comment

Order of Layers: Conductor, Insulation, Shield, Sheath, Bedding, Amor, Jacket

Dimensions

Conductor Construction ConRnd Diameter 0 inch

Insulation None Thickness 0 mil

Shield/Screen Not Shielded Max Stress V/mil

Filler None

Amor None

Bedding None

Sheath None

Jacket None

Cable None Max Induced V/1000ft

Diameter 2 inch

DC Resistance

Rdc 0 micro Ohms per foot

Cable Pulling

lbs/1000ft	lbs/kcmil	lbs/ft
Weight 0	Max. Tension 0	Max. Sidewall 0

OK Cancel



Questions

- Next steps

-

Feedback and Updates

- Tasks: Updates
 - Bell:
 - Liam:
 - Eli:
 - Baylor:
 - Eduardo:
 - Chicheng:

